

**CATSKILL WATERSHED CORPORATION**  
**Wastewater / Stormwater Committee Agenda**  
**Tuesday, March 4, 2025 @ 9:00AM**

- I. Call to Order
- II. Review minutes from February 4, 2025 meeting
- III. Wastewater / Stormwater

## **1. Community Wastewater Management Program**

### **General Project Updates:**

#### **CWMP III**

New Kingston  
Halcottsville  
Shokan

## **2. Future Stormwater Program**

### **Walton Central School District-O&M**

**Program:** Future Stormwater

**Address:** 47-49 Stockton Avenue, Walton NY

**Engineer:** William Gorham

**Contractor:** Burrells Excavating

### **Project Description:**

On June 22, 2022 NYC DEP approved a Stormwater Pollution Prevention Plan (SWPPP) for the The Walton Central School District's parking lot expansion project. On October 4, 2022 the CWC Board approved Six Hundred Forty-Seven Thousand Twenty-Five Dollars (\$647,025) for 50% of the costs of designing and implementing the SWPPP. The project is completed and came in under budget by One Hundred Fourteen Thousand Nine Hundred Six Dollars (\$114,906). On December 5, 2023 NYC DEP issued the construction acceptance letter for the site.

The scope of work at Walton Central School District included reconfiguring and expanding existing parking lots to improve traffic flows and add parking spaces. Stormwater components constructed included stone diaphragms, grass filter strips, four bioretention basins and plantings, and three Contech Filterra units.

On February 12, 2025 Walton Central School District submitted an application for operation and maintenance. Yearly maintenance estimates total Seventeen Thousand Nine Hundred Eighteen Dollars and Fifty-Eight Cents (\$17,918.58) of which 50% is eligible or Eight Thousand Nine Hundred Fifty-Nine Dollars and Twenty-Nine Cents (\$8,959.29). CWC extends the yearly estimate to reflect a 5 year maintenance contract or Forty-Four Thousand Seven Hundred Ninety-Six Dollars and Forty-Five Cents (\$44,796.45).

The CWC recommends reimbursement of up to Forty-Four Thousand Seven Hundred Ninety-Six Dollars and Forty-Five Cents (\$44,796.45) to Walton Central School District for 5 years of operation and maintenance costs associated with implementing a SWPPP required by NYC Watershed Regulations and the NYS DEC General Permit.

**Recommended Future Stormwater Funding not-to-exceed \$44,796.45**

### **3. Stormwater Retrofit Program**

### **4. Local Flood Hazard Mitigation**

**Property Owner:** Robert Drake

**Contact Person:** Same

**Address:** 46 State Rt. 214, Phoenicia, NY 12464

**LFA Recommendation:** Yes

**Project Category:** Property Protection Measures

**Phase:** Construction Funding

**Project Description:**

Robert Drake of 46 State Rt. 214 in Phoenicia is requesting Construction funding in the amount of \$61,710.00 to complete flood protection measures to his residence. Robert has already applied and was approved for funding from CWC to complete the Feasibility Study and Design for this work. The work will consist of removal of the existing boiler from the basement and oil tank. All hookups needed in a newly constructed first floor utility room for the owner purchased propane boiler. Relocation of the electrical service and panel to the first floor and waterproofing of any outlets that remain below the BFE.

Upon a site visit high water marks were clearly seen to be approximately 5' up the basement walls.

The Town of Shandaken completed and accepted their Local Flood Analysis (LFA) in 2016 for the hamlet of Phoenicia.

Robert will also be providing applications to anchor both propane tanks that are on the property. CWC staff recommends the construction funding for these flood protection measures.

### **5. Other:**

IV. Next meeting scheduled for Tuesday, April 1, 2025 @ 9:00AM

V. Adjournment